

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 11:33 am

PWS ID: UTAH02006 **Name:** DEWEYVILLE TOWN
Legal Contact: DEWEYVILLE
 LYNN J STEWART
Address: 10870 N HWY 38
 DEWEYVILLE, UT 84309
Phone Number: 435-257-5011
City Served (Area):
County: BOX ELDER COUNTY
System Type: Community
Activity Status Cd: Active
Population: 318
Rating: Approved
Rating Date: 04/15/2005
Activity Status: Active
Last Inv Update: 12/27/2010
Last Snty Srv Dt: 11/11/2008
Surveyor: MICHAEL MORTENSEN
Oper Period: 1/1 to 12/31
Avg Daily Prod:
Total Dsgn Cap:
Total Emerg Cap:

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	STEWART, LYNN J		435-257-9922	435-257-8543	lynnstewart@frontiernet.net

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered	0	121
			121 Total Svc Connections

Storage

Total Storage: 800,000 GAL **Number of Units:** 3 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST003	2008 NORTH TANK	Ground	500,000 GAL	Concrete		A	NO
ST001	NORTH TANK	Ground	100,000 GAL	Concrete		A	NO
ST002	SOUTH TANK	Ground	200,000 GAL	Concrete		A	NO

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	DEWEYVILLE CHLORINATOR		A	
TP002	EAST SPRING TABLET CHLORINATOR		A	
TP005	WELL 2 CHLORINATOR		A	

Distribution System

Pump Type	Total Dyn Head ft H2O P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	COLD WATER CANYON SPF	Active	SP				Yes	GW	Permanent	1/1 to 12/31	
WS002	NORTH CANYON SPRING	Active	SP				Yes	GW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS003	DEWEYVILLE WELL	Active	WL	6	150 GPM	150 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS004	EAST SPRING	Active	SP				Yes	GW	Permanent	1/1 to 12/31	
WS005	WELL # 2	Active	WL	10	506 GPM		Yes	GW	Permanent	1/1 to 12/31	

**Reports measured flow for wells, approved design capacity for all other sources.*